

ADDENDUM NO. 2

Florida City American Rescue Plan Act – Rehabilitation of Elevated Tank
ENGINEER'S PROJECT NUMBER: 23-019.03

August 13, 2024

1. Please note that the rehabilitation of the Clear Wells was removed from the project, the rehabilitation works are going to be only in the Elevated Tank. See the revised Project Manual and Procurement Bid/Proposal Form.
2. The Procurement Bid/Proposal Form has been revised as follows:
 - Items 17, 18, 19 & 20 were removed from the Procurement Bid/Proposal Form.
 - Item 10 was modified.See the revised Procurement Bid/Proposal Form.
3. The number of days for the completion of the project was modified. This project shall be completed within 180 days. See the revised Project Manual.
4. The sketch of the Elevated Tank was revised. See the revised sketch.
5. In Exhibit 1 of Project Manual – section “12. SMALL AND MINORITY BUSINESS, WOMEN'S BUSINESS ENTERPRISES, AND LABOR SURPLUS AREA FIRMS”, please note that there is not a required percentage for small business, Minority business (MBE), Women's business enterprises (WBE).
6. The anticipated start date for the project is October 12th, 2024.
7. Please note that there is not a specific paint system provided. It will be the contractor's responsibility to proceed with the most accurate methods to ensure the quality of the work.
8. The antennas on the tank will be removed prior to the project start.
9. Containment during the exterior renovation of the tank will not be required.
10. The existing coating does not contain lead on either the interior or the exterior.
11. In the Terms and Conditions section 20. Sub-Contractor, please note that the 30% of subcontracted work limit was removed. See the revised Project Manual.
12. The Special Provisions Section I-C. Subcontracts was replaced. See the revised Project Manual.